

M&V: Using Option B vs. Using Option C



Alberto Guerrero
Product Specialist
EnergyCAP



John Heinz
VP, Strategic Accounts
EnergyCAP





Agenda

- ✓ What is M&V?
- ✓ Available IPMVP Options
- ✓ Benefits of Option B
- ✓ Case study of Option B
- ✓ Benefits of Option C
- ✓ Case study of Option C

What is M&V?

What is M&V?


M&V is a standardized procedure, regulated by ISO 50015:2014 (Measurement and Verification of Energy Performance) and included in the framework of ISO 50001:

“The purpose of M&V is to provide confidence to interested parties that reported results are credible... [including] appropriate accuracy and management of uncertainty” (ISO 50015)

Why is M&V important?


“Measurement and verification” (M&V) of energy and cost savings resulting from an energy efficiency initiative is necessary because you can’t simply compare year-to-year out of pocket expenditures.

You have to compare **what you did spend** with how much **you would have spent** in the absence of energy efficiency, in other words how much you avoided spending.



ISO 50001: 2011 Energy Management

ISO 50001 creates a broad framework for an organization to implement an energy reduction program using the ISO PDCA continuous improvement process.



Available IPMVP Options

ISO 50015 and IPMVP

ISO 50015 “does not specify calculation methods”, it only establishes a common set of principles and guidelines.

The M&V practitioner selects the calculation methods and obtains approval by the parties involved via the M&V Plan.

Historically the most common calculation methods have been those in IPMVP, managed by an international nonprofit agency called The Efficiency Valuation Organization.

www.EVO-World.org

IPMVP Options

Retrofit Isolation



OPTION A
Retrofit Isolation:
Key Parameter(s) Measurement

OPTION B
Retrofit Isolation:
All Parameter Measurement

Whole Facility



OPTION C
Whole Facility

OPTION D
Calibrated Simulation

Benefits of Option B

Option B // Retrofit isolation

All parameters associated with the energy conservation measure must be measured and cannot be estimated. In other words, you are creating an M&V project which focuses only on some appliances/circuits and not on the entire building's power consumption.

For example, consider the installation of a variable speed drive. The power drawn as well as the hours of operation will have to be measured in order to determine any energy savings.

Option B // Retrofit isolation pros and cons

PROS:

- + Savings reports correlate closely with production changes
- + Actual savings determined from direct metered usage

CONS:

- Not reconciled to total facility utility costs
- The calculation of baselines for complex processes can be challenging
- ✗ Requires extensive metering

Case Study Option B

New Zealand based BMS specialist

SmartAnalytics M&V streamlines ECM evaluation and reporting for New Zealand based BMS specialist



Success story // The project


Auckland University of Technology, WO Building

Area: 10,472 m² - ~113k sq ft

Energy Usage: ~1,302,821 kWh/year

Energy Cost: ~180k NZD/year (~110k\$)

Optimization Target: 10% savings




The ECMs

Replacement of chiller and cooling tower

Adjustments to Air Handling Units (AHU)

- Supply air pressure and temperatures setpoints reset
- Disabled after-hours AHU requirement during weekends
- AHU Modulation Controller changed from PI to PID



Results



20.4%

Energy and
CO2e emission saved



NZD 34,440

Annual savings
(~23k\$)



7.5 years

Est. Payback period

Next steps

**Continue
monitoring**

Avoid slip
backs


**Investigate further
energy saving
opportunities**

Maintain building
performance

**Commence work
on other university
buildings**



Incorporate
lessons learned

Option B (screenshots): Measurements & Verification Tool



Option B (screenshots): Step by Step Process

1 - Project Definition
2 - ECM
3 - Baseline Period
4 - Reporting Period
5 - Routine Adjustments
6 - Non-Routine Adjustments
7 - Model
8 - Savings
9 - Executive Summary
Download Report



Option B (screenshots): Step 1 - Project Definition

Define the project's general overall parameters.

Name *


Methodology * IPMVP Option B ⓘ

Cost \$

Visible to other people ☐

The following text should describe the motivation for the project and provide some context. It does not need a summary as one can be entered in the M&V tools last step. You may add images and format the text within this text box, the formatting will be visible in the final report.

M&V Plan for Auckland University of Technology WO Building, located in Auckland Central Business District.



Actions taken on included:

- Replacing the Chiller and cooling tower (see picture)
- Disable after-hours and weekend AHU requirements
- Switch AHU modulation control from PI to PID
- Reset supply air pressure and temperatures set points

Option B (screenshots): Step 2 - ECM

Optimization and Efficiency Program

Name *

Optimization and Efficiency Program

Reference

Start *

01/02/2019

End *

17/02/2019

Describe the work carried out. You may add images and format the text within this text-box, the formatting will be visible in the final report.

↶

↷

<>

¶

B

I

U

↺

☰

☷

☰

☷

🖼️

🔗

📊

🔗

☰

—


↗

Renovations were carried on during the cooling season, as soon as works got authorized.

The new chiller was installed in parallel to the previous so to ensure continuity in the service, then the existing one was decommissioned.

ENERGYCAP · © EnergyCAP, LLC


Option B (screenshots): Step 3 - Baseline Period



Option B (screenshots): Step 4 - Reporting Period



Option B (screenshots): Step 5 - Routine Adjustments



Option B (screenshots): Step 6 - Non-Routine Adjustments

6 – Non-Routine Adjustments

Specify adjustments that need to be performed to the predicted consumption according circumstances or events not trackable through the routine adjustments.

New Static Factor




No static factors set in this project.

Option B (screenshots): Step 7 - Model



Option B (screenshots): Step 8 - Savings



Option B (screenshots): Step 9 - Executive Summary

↶ ↷ ⌂ B I U $\frac{\Box}{\Box}$ ☰ ☷ ⌵ ⌶ 🖼️ 📎 📊 🔁 ⌵ ⌶ ↶ ↷

The energy conservation measures implemented resulted in savings that far exceed the initial target of 10% kWh savings per year. Project results demonstrate a 20% reduction in energy use after 1 year; NZ\$ 37,272 per annum (US\$ 23,477 / €21,446) in cost savings and a payback period for HVAC optimization of 6.9 years.

The personnel on site and energy analysts involved are dedicated toward maintaining the savings achieved so far, through continuous monitoring and analysis, also investigating further energy-using entities to improve savings while maintaining optimal performance within the WO building.

As a result of the savings achieved under the pilot project, AUT has committed to work on additional buildings located at the university campus.

Benefits of Option C

Option C // Whole facility



This approach is taken where the energy use of the whole facility needs to be measured. Several independent variables may need to be considered such as heating/cooling degree days, changes in floor area, hours of operation, use of spaces, occupancy, etc...

Option C is of value where several energy conservation measures have been introduced and the overall picture for the facility is required or you only have utility bill information.



Easy to get started and to do portfolio-wide savings reporting.

Option C // Whole facility pros and cons

PROS:

-  Evaluates performances of the entire facility
-  Factors in interactions amongst ECMs and between ECMs and the rest of the facility

CONS:

-  No separation of impacts from different ECMs
-  Impact on savings coming from unexplained variations of energy usage can be difficult to capture

 Easy access to utility bill data

Option C methodology in UtilityManagement

Establish baseline from utility bills

Determine weather sensitivity


Calendarize bills – adjust for billing length

Adjust for floor area

Special adjustments

Apply cost – today's unit cost

Consider other savings – rebates, refund, demand response, rate reduction...



Case Study Option C

Neil Armstrong Elementary School

UtilityManagement M&V verifies energy savings from behaviour-based program for Virginia school district



Success story // The project


Neil Armstrong Elementary School

Area: 80,000 ft² = ~7,432 m²

Energy Usage in Base Year: 3,805,228 Kbtu/year

Energy Cost in Base Year: \$81,608

Optimization Target: 15% savings



Success story // The project

Zero-Cost Energy Conservation Opportunities

- System schedules
- Turn off lights
- Turn off computers and monitors
- Seasonal water temperature adjustments
- Economizers
- Take advantage of natural light

Low-Cost Energy Conservation Opportunities


- Programmable thermostats
- Repair broken valves
- Occupancy sensors for lighting, HVAC
- Reduce lamps in over-lighted areas
- Use rebated programs for lighting upgrades
- Calibrate sensors

Establish Baseline

Settings


Baseline start

02/01/2013




Baseline length

12 months




Savings start

02/01/2014



Method


Current Average Unit Cost




☒ Adjust by Floor Area


Pre-baseline years added to weather analysis


0 years




Cool above 

60°F




Heat below 

55°F




Adjust for weather

Electricity



Natural Gas




● data point ■ outlier ○ user-removed — best fit — 2 standard deviations — base load

i Statistics are compliant with **IPMVP Option C**


Make special adjustments

		Start	End	Frequency	Value	Category	Method
▼	1	06/01/2014	06/30/2014	Continuous	15.5000	Schedule Change	Add 15.5% to the total BATCC use
AST Additional Occupied Days - CE							
▼	2	10/01/2016	12/31/2016	Continuous	1.7000	Occupancy	Add 1.7% to the total BATCC use
A-170727-4777 Community Use JWN 170727*updated per FCPS. Ssmith 05142019							
▼	4	01/01/2018	01/31/2018	Continuous	160.0300	Extreme Weather	Add 160.03 per day to the BATCC non-weather use
January 2018 additional runtime							

Calculate the savings



Calculate the savings



Other Savings

Edit Other Savings

Cancel

Save

Category

Utility Rate Reduction

▼

Add New...

+

Demand Response

Meter Consolidation

Other

Rebate

Refund

Utility Rate Reduction

Description

comment

Edit Other Savings

Cancel

Save

Category

Utility Rate Reduction

▼

Amount

\$ 100

Frequency

continuous

Start

Jan 2022

End


Jan 2023

Description


comment

Date	Non-weather use		Weather use		Cost		Floor area	Adjustments		Weather	Cooling degree days		Heating degree days	
	Baseline	BATCC	Baseline	BATCC	BATCC	AUC		Special	Other		Baseline	Current	Baseline	Current
> 07/05/2022	2,069.2 kWh	2,654.2 kWh	2,318.8 kWh	0.0 kWh	\$ 282.98	\$ 0.107		✓	✓		10	0	0	0
> 07/06/2022	2,069.2 kWh	2,654.2 kWh	1,159.4 kWh	0.0 kWh	\$ 282.98	\$ 0.107		✓	✓		5	0	0	0
> 07/07/2022	2,069.2 kWh	2,654.2 kWh	463.8 kWh	0.0 kWh	\$ 282.98	\$ 0.107		✓	✓		2	0	0	0
> 07/08/2022	2,069.2 kWh	2,654.2 kWh	927.5 kWh	0.0 kWh	\$ 282.98	\$ 0.107		✓	✓		4	0	0	0
> 07/09/2022	2,202.1 kWh	2,787.1 kWh	695.6 kWh	0.0 kWh	\$ 297.14	\$ 0.107		✓	✓		3	0	0	0
> 07/10/2022	2,202.1 kWh	2,787.1 kWh	0.0 kWh	0.0 kWh	\$ 297.14	\$ 0.107		✓	✓		0	0	0	0

Report to stakeholders



Historical & Baseline



Performance

Report to stakeholders

Cost Savings

Savings (BATCC - Actual)

\$189,870.45

BATCC (Baseline)

\$889,663.99

Actual Cost

\$699,793.54


↑21.3%

Inception–Feb 2024

Optimization Target: 15% savings

Realized Savings: 21.3% savings, \$189,870

Cost Avoidance by Commodity



Fiscal Years 2021–2024


Data details Filters applied

Copy table data

Commodity Savings

⚡ Electric	\$170,492.51
🔥 Natural Gas	\$12,759.28
🚰 Sewer	\$8,147.71
💧 Water	⚠️ -\$1,529.06

Cost Avoidance Summary



Fiscal Years 2021–2025


Data details Filters applied

Copy table data

Year Savings

2021	\$44,311.75
2022	\$20,826.07
2023	\$16,236.44
2024YTD	\$8,440.39

Use Avoidance Summary



Fiscal Years 2021–2025


Data details Filters applied

Copy table data

Year Savings (kWh)

2021	354,735.00
2022	181,260.00
2023	181,964.00
2024YTD	54,321.00

Report to stakeholders



Cost Avoidance by Building	BATCC Cost	Actual Cost	Cost Avoidance	Cost Avoidance %
Hayfield Secondary School [HAYFS-180]	\$8,805,768	\$5,799,630	\$3,006,138	34.1%
Woodson High School [WO-130]	\$8,498,292	\$6,053,448	\$2,444,844	28.8%
Lake Braddock Secondary School [LAKEB-400]	\$10,642,732	\$8,249,676	\$2,393,056	22.5%
Chantilly High School [CHAN-250]	\$7,492,762	\$5,307,614	\$2,185,148	29.2%
Westfield High School [WESTFHS-240]	\$7,912,566	\$5,780,307	\$2,132,259	26.9%
Fairfax High School [FAIR-500]	\$7,527,953	\$5,469,121	\$2,058,832	27.3%
Sandburg Middle School [SAND-231]	\$4,803,949	\$2,901,226	\$1,902,723	39.6%
South County High School [SOCOHS-420]	\$6,637,646	\$5,028,835	\$1,608,811	24.2%
Robinson Secondary School [ROBI-390]	\$8,437,283	\$6,832,473	\$1,604,809	19.0%
Edison High School [ED-120]	\$6,233,094	\$4,710,029	\$1,523,065	24.4%
West Potomac High School [WESTP-200]	\$6,712,666	\$5,286,071	\$1,426,596	21.3%
Kilmer Middle School [KILM-071]	\$3,452,068	\$2,026,381	\$1,425,687	41.3%
Mount Vernon High School [MTVE-220]	\$6,891,600	\$5,474,620	\$1,416,980	20.6%
South Lakes High School [SOUT-320]	\$6,548,885	\$5,177,641	\$1,371,244	20.9%
Liberty Middle School [LIBER-411]	\$3,494,269	\$2,190,545	\$1,303,724	37.3%
Marshall High School [MARS-070]	\$5,327,331	\$4,024,304	\$1,303,027	24.5%
Annandale High School [ANNA-140]	\$5,404,948	\$4,264,075	\$1,140,874	21.1%
Poe Middle School [POE-141]	\$3,245,123	\$2,158,872	\$1,086,251	33.5%
Jefferson High School for Science and Technology [JEFF-340]	\$4,891,405	\$3,841,085	\$1,050,320	21.5%
Lewis High School [LEWI-160]	\$5,240,593	\$4,260,360	\$980,233	18.7%
Centreville High School [CENTHS-410]	\$4,609,621	\$3,689,946	\$919,676	20.0%
Whitman Middle School [WHITM-221]	\$2,924,856	\$2,017,082	\$907,774	31.0%
McLean High School [MCLE-030]	\$4,699,894	\$3,819,481	\$880,413	18.7%
Carson Middle School [CARS-171]	\$3,464,641	\$2,624,765	\$839,876	24.2%
Madison High School [MADI-060]	\$5,013,273	\$4,196,451	\$816,822	16.3%
Fort Belvoir Primary Elementary School [FTBV-197]	\$2,465,178	\$1,685,886	\$779,292	31.6%
Franklin Middle School [FRANM-331]	\$2,193,648	\$1,443,207	\$750,441	34.2%
Holmes Middle School [HOLM-111]	\$2,941,223	\$2,234,403	\$706,820	24.0%

Resources

Become a member of EVO ([**www.EVO-World.org**](http://www.EVO-World.org))

Download IPMVP from EVO

Purchase ISO standards at iso.org

Become a CMVP-Certified Measurement & Verification Professional ([**www.AEECenter.org**](http://www.AEECenter.org))

Check out EnergyCAP's resources and have a tour of ESA and EUM

Questions?



CATALYST '24



Session survey